

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
Region III, Wheeling Field Office

SUBJECT: Drinking Water Analyses of Samples Taken in the Llangollen Well Field in the Wilmington, Delaware Area DATE: May 18, 1977

FROM: William F. Gerstine (3SM12) *W.F.G.*  
Chemist, Laboratory Section  
Wheeling Field Office

TO: Larry A. Parker (3SM12) *Larry A. Parker*  
Chief, Laboratory Section  
Wheeling Field Office

cc: **ORIGINAL**  
**(Red)**

Sample Description	Date	Time	Carbon Tetrachloride conc., $\mu\text{g/l}$	Chloroform conc., $\mu\text{g/l}$	Methylene Chloride conc., $\mu\text{g/l}$
* Finished Water -	5/13/77	0845	Trace (<1)	38	6.5
** Llangollen Landfill Well Field					
Well #7 - Llangollen Well Field	5/13/77	0850	N.D.	N.D.	N.D.
Well #2 - Llangollen Well Field	5/13/77	0910	N.D.	N.D.	N.D.
Well G-5 - Llangollen Landfill	5/13/77	0930	N.D.	N.D.	N.D.
*Rerun of same sample at 1:5 dilution	5/13/77	0845	N.D.	N.D.	6.0
**Rerun of same sample after 3 days storage with no head space	5/13/77	0845	N.D.	1	2.4

cc: JLD  
HRP

RECEIVED

JUN 15 1977  
R&D DIVISION  
EPA, REGION III